



ST GEORGES CAY POWER COMPANY (SGCPC)
TERMS & CONDITIONS FOR CUSTOMER-OWNED PV SYSTEMS
OPERATED UNDER A GRID-INTERCONNECTION AGREEMENT (GIA)

The Customer agrees to comply always as follows related to the operation of their PV System (the “system”).

1. Operate and maintain (or engage services of qualified technician and/or engineer as may be required to operate and/or maintain) the system in accordance with all applicable Governmental standards and requirements and the instructions of the manufacturers of the equipment used to construct the various components of the system.
2. Comply with SGCPC requirements relating to the operation of the system which may be in effect from time to time.
3. Promptly notify SGCPC of any malfunction or breakdown of any component of the system that could constitute a foreseeable safety hazard, or which could reasonably be expected to cause disturbance or damage to the SGCPC Grid.
4. Not operate or allow the system to be operated so as to generate electricity at a rate greater than 110% of the system Nameplate Gross Power Rating as noted on the GIA.
5. Not add to or modify or allow any addition or modification to the system without the prior written consent of SGCPC.
6. Not alter, modify, tamper, or allow any alteration, modification or tampering with the system connection to the SGCPC Grid without SGCPC prior written consent. This includes the SGCPC-owned meter, service disconnect, AC disconnect or interconnection, and any Customer-owned Transfer Switch.
7. Not relocate or interconnect or allow any relocation or interconnection of the system to the SGCPC Grid at any location other than the Service Address without SGCPC prior written consent.
8. Not convey or distribute electricity or allow same across premise boundaries or property lines; specifically that the electricity produced by the system shall be consumed on the Customer premise by Customer loads on the Customer’s property; unless it is an approved PV System and is exporting energy to the SGCPC Grid through the SGCPC bi-directional meter.
9. Allow access to SGCPC technicians to system components on the utility side of the meter at any time when it is deemed necessary for safety or otherwise for inspection or testing during normal business hours.
10. Make all payments required under the approved REP program plans.

Signature below indicates acceptance of Terms and Conditions

Signature _____

Name _____

Address _____

Date _____